





LIMIT STATES DESIGN
CANADA



TALL WALL SPECIFIER GUIDE CLIMATIC DATA



Boise Cascade
Engineered Wood Products



City	S _s (kPa)	S _r (kPa)	Seismic Data	q _{1/50} (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
			S _s (0.2)		9.4.2.2 NBCC 2010	Open terrain	Rough terrain
100 Mile House	2.6	0.3		0.35	37	22	16
Abbotsford *	2.0	0.3	0.99	0.44	30	28	20
Agassiz	2.4	0.7		0.47	43	30	21
Alberni *	3.0	0.4	0.75	0.32	43	21	15
Ashcroft	1.7	0.1		0.38	22	24	17
Beaton River	3.3	0.1		0.30	40	19	14
Burns Lake	3.4	0.2		0.39	44	25	18
Cache Creek	1.7	0.2		0.39	24	25	18
Campbell River	3.3	0.4		0.52	47	33	23
Carmi	3.9	0.2		0.38	49	24	17
Castlegar	4.2	0.1		0.34	51	22	15
Chetwynd	2.4	0.2		0.40	32	26	18
Chilliwack *	2.2	0.3	0.76	0.47	32	30	21
Comox	2.6	0.4		0.52	39	33	23
Courtenay	2.6	0.4		0.52	39	33	23
Cranbrook	3.0	0.2		0.33	39	21	15
Crescent Valley	4.2	0.1		0.33	51	21	15
Crofton *	1.8	0.2	1.1	0.40	25	26	18
Dawson Creek	2.5	0.2		0.40	33	26	18
Dog Creek	1.8	0.2		0.35	25	22	16
Duncan *	1.8	0.4	1.1	0.39	30	25	18
Elko	3.6	0.2		0.40	46	26	18
Fernie	4.5	0.2		0.40	56	26	18
Fort Nelson	2.4	0.1		0.30	30	19	14
Fort St-John	2.8	0.1		0.39	35	25	18
Glacier	9.4	0.2		0.32	113	21	15
Golden	3.7	0.2		0.35	47	22	16
Grand Forks	2.8	0.1		0.40	35	26	18
Greenwood	4.0	0.1		0.40	49	26	18
Hope	2.8	0.7		0.63	47	40	28
Kamloops	1.8	0.2		0.40	25	26	18
Kaslo	2.8	0.1		0.31	35	20	14
Kelowna	1.7	0.1		0.40	22	26	18
Kimberley	3.0	0.2		0.33	39	21	15
Kitimat Townsite	6.5	0.8		0.48	92	31	22
Lillooet	2.1	0.1		0.44	27	28	20
Lytho	2.8	0.3		0.43	39	27	19
Mackenzie	5.1	0.2		0.32	63	21	15
Masset	1.8	0.4		0.61	30	39	27
McBride	4.3	0.2		0.35	54	22	16
McLeod Lake	4.1	0.2		0.32	52	21	15
Merritt	1.8	0.3		0.44	27	28	20
Mission City *	2.4	0.3	0.93	0.43	34	27	19
Montrose	4.1	0.1		0.35	50	22	16
Nakusp	4.4	0.1		0.33	53	21	15
Nanaimo *	2.3	0.4	1	0.50	35	32	22
Nelson	4.2	0.1		0.33	51	21	15
Ocean Falls	3.9	0.8		0.59	62	37	26
Osoyoos	1.1	0.1		0.40	20	26	18
Penticton	1.3	0.1		0.45	20	29	20
Port Alberni *	3.0	0.4	0.76	0.32	43	21	15

City	S _s (kPa)	S _r (kPa)	Seismic Data	q _{1/50} (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
			S _a (0.2)		9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Port Hardy	0.9	0.4		0.52	20	33	23
Port McNeill	1.1	0.4		0.52	21	33	23
Powell River	1.9	0.4		0.51	31	32	23
Prince George	3.4	0.2		0.37	44	24	17
Prince Rupert	1.9	0.4		0.54	31	34	24
Princeton	2.9	0.6		0.36	46	23	16
Qualicum Beach *	2.2	0.4	0.82	0.52	34	33	23
Quesnel	3.0	0.1		0.31	37	20	14
Revelstoke	5.8	0.1		0.32	69	21	15
Salmon Arm	3.5	0.1		0.39	43	25	18
Sandspit	1.8	0.4		0.78	30	49	35
Sidney *	1.1	0.2	1.2	0.42	20	27	19
Smith River	2.8	0.1		0.30	35	19	14
Smithers	3.2	0.2		0.40	41	26	18
Squamish *	3.2	0.7	0.72	0.50	52	32	22
Stewart	7.9	0.8		0.36	108	23	16
Taylor	2.3	0.1		0.40	29	26	18
Terrace	5.4	0.6		0.36	75	23	16
Tofino *	1.1	0.4	1.2	0.68	21	43	30
Trail	4.1	0.1		0.35	50	22	16
Ucluelet *	1.0	0.4	1.2	0.68	20	43	30
Vernon	2.2	0.1		0.40	28	26	18
Victoria *	2.1	0.3	1.2	0.63	31	40	28
North Vancouver *	3.0	0.3	0.88	0.45	41	29	20
Vancouver Region - Burnaby *	2.9	0.7	0.93	0.47	48	30	21
Vancouver Region - Cloverdale *	2.5	0.2	1.1	0.44	33	28	20
Vancouver Region - Haney *	2.4	0.2	0.97	0.44	32	28	20
Vancouver Region - Ladner *	1.3	0.2	1.1	0.46	20	29	21
Vancouver Region - Langley *	2.4	0.2	1.1	0.44	32	28	20
Vancouver Region - New Westminster *	2.3	0.2	0.99	0.44	31	28	20
Vancouver Region - Richmond *	1.5	0.2	1	0.45	22	29	20
Vancouver Region - Surrey *	2.4	0.3	1	0.44	34	28	20
Vancouver City Hall *	1.8	0.2	0.94	0.45	25	29	20
West Vancouver *	2.4	0.2	0.88	0.48	32	31	22
White Rock*	2.0	0.2	1	0.44	28	28	20
Williams Lake	2.4	0.2		0.35	32	22	16
Youbou *	3.9	0.7	1	0.32	60	21	15

* Bracing to resist lateral loads due to earthquake should be provided (as per Part 4 of NBCC 2010 or accepted practices)

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Athabasca	1.5	0.1	0.36	20	23	16
Banff	3.6	0.1	0.32	44	21	15
Barrhead	1.7	0.1	0.44	22	28	20
Beaverlodge	2.4	0.1	0.36	30	23	16
Brooks	1.2	0.1	0.52	20	33	23
Calgary	1.1	0.1	0.48	20	31	22
Campsie	1.7	0.1	0.44	22	28	20
Camrose	2.0	0.1	0.39	26	25	18
Cardston	1.5	0.1	0.72	20	46	32
Claresholm	1.3	0.1	0.58	20	37	26
Cold Lake	1.7	0.1	0.38	22	24	17
Coleman	2.7	0.3	0.63	38	40	28
Coronation	2.2	0.1	0.37	28	24	17
Cowley *	1.6	0.1	1.10	21	69	49
Drumheller	1.2	0.1	0.44	20	28	20
Edmonton	1.7	0.1	0.45	22	29	20
Edson	2.1	0.1	0.46	27	29	21
Embarras Portage	1.9	0.1	0.37	24	24	17
Fairview	2.6	0.1	0.35	32	22	16
Fort MacLeod	1.2	0.1	0.68	20	43	30
Fort McMurray	1.4	0.1	0.35	20	22	16
Fort Saskatchewan	1.6	0.1	0.43	21	27	19
Fort Vermilion	2.1	0.1	0.30	27	19	14
Grande Prairie	2.2	0.1	0.43	28	27	19
Habay	2.4	0.1	0.30	30	19	14
Hardisty	1.7	0.1	0.36	22	23	16
High River	1.3	0.1	0.65	20	41	29
Hinton	2.9	0.1	0.46	36	29	21
Jasper	3.3	0.1	0.32	40	21	15
Keg River	2.4	0.1	0.30	30	19	14
Lac la Biche	1.6	0.1	0.36	21	23	16
Lacombe	2.1	0.1	0.40	27	26	18
Lethbridge	1.2	0.1	0.66	20	42	29
Manning	2.3	0.1	0.30	29	19	14
Medicine Hat	1.1	0.1	0.48	20	31	22
Peace River	2.2	0.1	0.32	28	21	15
Pincher Creek *	1.5	0.1	0.96	20	61	43
Ranfurly	1.9	0.1	0.36	24	23	16
Red Deer	2.0	0.1	0.40	26	26	18
Rocky Mountain House	1.9	0.1	0.36	24	23	16
Slave Lake	1.9	0.1	0.37	24	24	17
Stettler	2.2	0.1	0.36	28	23	16
Stony Plain	1.7	0.1	0.45	22	29	20
Suffield	1.3	0.1	0.49	20	31	22
Taber	1.2	0.1	0.63	20	40	28
Turner Valley	1.4	0.1	0.65	20	41	29
Valleyview	2.3	0.1	0.42	29	27	19
Vegreville	1.9	0.1	0.36	24	23	16
Vermilion	1.7	0.1	0.36	22	23	16
Wagner	1.9	0.1	0.37	24	24	17

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Wainwright	2.0	0.1	0.36	26	23	16
Wetaskiwin	2.0	0.1	0.39	26	25	18
Whitecourt	1.9	0.1	0.37	24	24	17
Wimborne	1.6	0.1	0.40	21	26	18

* Bracing to resist lateral loads due to wind should be provided (as per NBCC 2010 section 9.23.13)

SASKATCHEWAN

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Assiniboia	1.6	0.1	0.49	21	31	22
Batrum	1.2	0.1	0.54	20	34	24
Biggar	2.1	0.1	0.45	27	29	20
Broadview	1.7	0.1	0.46	22	29	21
Dafoe	1.7	0.1	0.37	22	24	17
Dundurn	1.5	0.1	0.46	20	29	21
Estevan	1.6	0.1	0.52	21	33	23
Hudson Bay	2.0	0.1	0.37	26	24	17
Humboldt	2.1	0.1	0.39	27	25	18
Island Falls	2.1	0.1	0.35	27	22	16
Kamsack	2.1	0.2	0.40	29	26	18
Kindersley	1.4	0.1	0.46	20	29	21
Lloydminster	2.0	0.1	0.40	26	26	18
Maple Creek	1.2	0.1	0.45	20	29	20
Meadow Lake	1.7	0.1	0.40	22	26	18
Melfort	2.1	0.1	0.36	27	23	16
Melville	1.7	0.1	0.40	22	26	18
Moose Jaw	1.4	0.1	0.52	20	33	23
Nipawin	2.0	0.1	0.38	26	24	17
North Battleford	1.7	0.1	0.46	22	29	21
Prince Albert	1.9	0.1	0.38	24	24	17
Qu'Appelle	1.7	0.1	0.42	22	27	19
Regina	1.4	0.1	0.49	20	31	22
Rosetown	1.7	0.1	0.49	22	31	22
Saskatoon	1.7	0.1	0.43	22	27	19
Scott	1.9	0.1	0.45	24	29	20
Strasbourg	1.5	0.1	0.42	20	27	19
Swift Current	1.4	0.1	0.54	20	34	24
Uranium City	2.0	0.1	0.36	26	23	16
Weyburn	1.4	0.1	0.48	20	31	22
Yorkton	1.7	0.1	0.40	22	26	18

MANITOBA

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Beausejour	1.9	0.2	0.41	27	26	18
Boissevain	2.2	0.2	0.52	30	33	23
Brandon	2.1	0.2	0.49	29	31	22
Churchill	2.8	0.2	0.55	37	35	25
Dauphin	1.9	0.2	0.40	27	26	18
Flin Flon	2.2	0.2	0.35	30	22	16
Gimli	1.9	0.2	0.40	27	26	18
Island Lake	2.6	0.2	0.35	35	22	16
Lac du Bonnet	1.9	0.2	0.37	27	24	17
Lynn Lake	2.4	0.2	0.37	32	24	17
Morden	2.2	0.2	0.52	30	33	23
Neepawa	2.2	0.2	0.44	30	28	20
Pine Falls	1.9	0.2	0.39	27	25	18
Portage la Prairie	2.1	0.2	0.46	29	29	21
Rivers	2.1	0.2	0.46	29	29	21
Sandilands	2.2	0.2	0.40	30	26	18
Selkirk	1.9	0.2	0.41	27	26	18
Split Lake	2.5	0.2	0.39	33	25	18
Steinbach	2.0	0.2	0.40	28	26	18
Swan River	2.0	0.2	0.35	28	22	16
The Pas	2.1	0.2	0.37	29	24	17
Thompson	2.4	0.2	0.36	32	23	16
Viriden	2.0	0.2	0.46	28	29	21
Winnipeg	1.9	0.2	0.45	27	29	20

ONTARIO

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Ailsa Craig	2.2	0.4	0.5	34	32	22
Ajax	1.0	0.4	0.48	20	31	22
Alexandria	2.4	0.4	0.4	36	26	18
Alliston	2.0	0.4	0.36	32	23	16
Almonte	2.5	0.4	0.41	38	26	18
Armstrong	2.7	0.4	0.3	40	19	14
Arnprior	2.5	0.4	0.37	38	24	17
Atikokan	2.4	0.3	0.3	34	19	14
Aurora	2.0	0.4	0.44	32	28	20
Bancroft	3.1	0.4	0.32	44	21	15
Barrie	2.5	0.4	0.36	38	23	16
Barriefield	2.1	0.4	0.47	33	30	21
Beaverton	2.2	0.4	0.36	34	23	16
Belleville	1.7	0.4	0.43	28	27	19
Belmont	1.7	0.4	0.51	28	32	23
Big Trout Lake	3.2	0.2	0.42	41	27	19
Bracebridge	3.1	0.4	0.35	44	22	16
Bradford	2.1	0.4	0.36	33	23	16
Brampton	1.3	0.4	0.44	24	28	20

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Brantford	1.3	0.4	0.42	24	27	19
Brighton	1.6	0.4	0.48	27	31	22
Brockville	2.2	0.4	0.44	34	28	20
Burk's Falls	2.7	0.4	0.35	40	22	16
Burlington	0.9	0.4	0.46	20	29	21
Cambridge	1.6	0.4	0.36	27	23	16
Campbellford	1.7	0.4	0.41	28	26	18
Cannington	2.2	0.4	0.36	34	23	16
Carleton Place	2.5	0.4	0.41	38	26	18
Cavan	2.0	0.4	0.44	32	28	20
Centralia	2.3	0.4	0.49	35	31	22
Chapleau	4.0	0.4	0.3	55	19	14
Chatham	1.0	0.4	0.43	20	27	19
Chesley	2.8	0.4	0.48	41	31	22
Clinton	2.6	0.4	0.49	39	31	22
Coboconk	2.5	0.4	0.35	38	22	16
Cobourg	1.2	0.4	0.49	23	31	22
Cochrane	2.8	0.3	0.35	39	22	16
Colborne	1.6	0.4	0.49	27	31	22
Collingwood	2.7	0.4	0.39	40	25	18
Cornwall	2.2	0.4	0.41	34	26	18
Corunna	1.0	0.4	0.47	20	30	21
Deep River	2.5	0.4	0.35	38	22	16
Deseronto	1.9	0.4	0.43	31	27	19
Dorchester	1.9	0.4	0.47	31	30	21
Dorion	2.8	0.4	0.39	41	25	18
Dresden	1.0	0.4	0.43	20	27	19
Dryden	2.4	0.3	0.3	34	19	14
Dunnville	2.0	0.4	0.46	32	29	21
Durham	2.8	0.4	0.44	41	28	20
Dutton	1.3	0.4	0.47	24	30	21
Earlton	2.6	0.4	0.45	39	29	20
Edison	2.4	0.3	0.31	34	20	14
Elmvale	2.6	0.4	0.36	39	23	16
Embro	2.0	0.4	0.48	32	31	22
Englehart	2.5	0.4	0.41	38	26	18
Espanola	2.3	0.4	0.42	35	27	19
Exeter	2.4	0.4	0.49	36	31	22
Fenelon Falls	2.3	0.4	0.36	35	23	16
Fergus	2.2	0.4	0.36	34	23	16
Forest	2.0	0.4	0.48	32	31	22
Fort Erie	2.6	0.4	0.46	39	29	21
Fort Frances	2.3	0.3	0.31	33	20	14
Gananoque	2.1	0.4	0.47	33	30	21
Geraldton	2.9	0.4	0.3	42	19	14
Glencoe	1.5	0.4	0.43	26	27	19
Goderich	2.4	0.4	0.55	36	35	25
Gore Bay	2.6	0.4	0.44	39	28	20
Graham	2.6	0.3	0.3	37	19	14
Gravenhurst (Muskoka Airport)	2.7	0.4	0.36	40	23	16

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Grimsby	0.9	0.4	0.46	20	29	21
Guelph	1.9	0.4	0.36	31	23	16
Guthrie	2.5	0.4	0.36	38	23	16
Haileybury	2.4	0.4	0.44	36	28	20
Haldimand	1.2	0.4	0.44	23	28	20
Haliburton	2.9	0.4	0.35	42	22	16
Halton Hills (Georgetown)	1.4	0.4	0.37	25	24	17
Hamilton	0.9	0.4	0.46	20	29	21
Hanover	2.6	0.4	0.48	39	31	22
Hastings	2.0	0.4	0.41	32	26	18
Hawkesbury	2.3	0.4	0.41	35	26	18
Hearst	2.8	0.3	0.28	39	18	13
Hey Harbour	2.7	0.4	0.39	40	25	18
Hornepayne	3.6	0.4	0.3	50	19	14
Huntsville	2.9	0.4	0.35	42	22	16
Ingersoll	1.7	0.4	0.48	28	31	22
Iroquois Falls	2.9	0.3	0.37	40	24	17
Jellicoe	2.7	0.4	0.3	40	19	14
Kapuskasing	2.8	0.3	0.31	39	20	14
Kemptville	2.3	0.4	0.41	35	26	18
Kenora	2.3	0.3	0.31	33	20	14
Killaloe	2.7	0.4	0.35	40	22	16
Kincardine	2.6	0.4	0.55	39	35	25
Kingston	2.1	0.4	0.47	33	30	21
Kinmount	2.7	0.4	0.35	40	22	16
Kirkland Lake	2.9	0.3	0.39	40	25	18
Kitchener	2.0	0.4	0.37	32	24	17
Lakefield	2.2	0.4	0.38	34	24	17
Lansdowne House	2.9	0.2	0.32	38	21	15
Leamington	0.8	0.4	0.47	20	30	21
Lindsay	2.3	0.4	0.38	35	24	17
Lion's Head	2.7	0.4	0.48	40	31	22
Listowel	2.6	0.4	0.47	39	30	21
London	1.9	0.4	0.47	31	30	21
Lucan	2.3	0.4	0.5	35	32	22
Maitland	2.2	0.4	0.44	34	28	20
Markdale	3.4	0.4	0.41	48	26	18
Markham	1.3	0.4	0.44	24	28	20
Martin	2.6	0.3	0.3	37	19	14
Matheson	2.8	0.3	0.39	39	25	18
Mattawa	2.1	0.4	0.32	33	21	15
Midland	2.7	0.4	0.39	40	25	18
Milton	1.3	0.4	0.43	24	27	19
Milverton	2.4	0.4	0.43	36	27	19
Minden	2.7	0.4	0.35	40	22	16
Mississauga	1.1	0.4	0.48	21	31	22
Mitchell	2.4	0.4	0.48	36	31	22
Moosonee	2.2	0.3	0.35	32	22	16
Morrisburg	2.3	0.4	0.41	35	26	18
Mount Forest	2.7	0.4	0.41	40	26	18

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Nakina	2.8	0.4	0.3	41	19	14
Nanticoke	1.4	0.4	0.48	25	31	22
Napanee	1.9	0.4	0.43	31	27	19
New Liskeard	2.3	0.4	0.43	35	27	19
Newcastle	1.5	0.4	0.48	26	31	22
Newmarket	2.0	0.4	0.38	32	24	17
Niagara Falls	2.0	0.4	0.43	32	27	19
North Bay	2.2	0.4	0.34	34	22	15
Norwood	2.1	0.4	0.41	33	26	18
Oakville	0.9	0.4	0.47	20	30	21
Orangeville	2.3	0.4	0.36	35	23	16
Orillia	2.4	0.4	0.36	36	23	16
Oshawa	1.4	0.4	0.48	25	31	22
Ottawa	2.4	0.4	0.41	36	26	18
Owen Sound	2.8	0.4	0.48	41	31	22
Pagwa River	2.4	0.4	0.3	36	19	14
Paris	1.4	0.4	0.42	25	27	19
Parkhill	2.1	0.4	0.5	33	32	22
Parry Sound	2.8	0.4	0.39	41	25	18
Pelham (Fonthill)	2.3	0.4	0.42	35	27	19
Pembroke	2.5	0.4	0.35	38	22	16
Penetanguishene	2.8	0.4	0.39	41	25	18
Perth	2.3	0.4	0.41	35	26	18
Petawawa	2.6	0.4	0.35	39	22	16
Peterborough	2.0	0.4	0.41	32	26	18
Petrolia	1.3	0.4	0.47	24	30	21
Pickering (Dunbarton)	1.0	0.4	0.48	20	31	22
Picton	2.0	0.4	0.49	32	31	22
Plattsville	1.9	0.4	0.42	31	27	19
Point Alexander	2.5	0.4	0.35	38	22	16
Prescott	2.2	0.4	0.44	34	28	20
Princeton	1.5	0.4	0.42	26	27	19
Raith	2.7	0.4	0.3	40	19	14
Rayside-Balfour (Chelmsford)	2.5	0.4	0.45	38	29	20
Red Lake	2.4	0.3	0.3	34	19	14
Renfrew	2.5	0.4	0.35	38	22	16
Richmond Hill	1.5	0.4	0.44	26	28	20
Rockland	2.4	0.4	0.4	36	26	18
Sarnia	1.1	0.4	0.47	21	30	21
Sault Ste. Marie	3.1	0.4	0.44	44	28	20
Schreiber	3.3	0.4	0.39	47	25	18
Seaforth	2.5	0.4	0.48	38	31	22
Simcoe	1.3	0.4	0.45	24	29	20
Sioux Lookout	2.4	0.3	0.3	34	19	14
Smiths Falls	2.3	0.4	0.41	35	26	18
Smithville	1.5	0.4	0.42	26	27	19
Smooth Rock Falls	2.7	0.3	0.32	38	21	15
South River	2.8	0.4	0.35	41	22	16
Southampton	2.7	0.4	0.53	40	34	24
St. Catharines	1.0	0.4	0.46	20	29	21

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
St. Mary's	2.2	0.4	0.47	34	30	21
St. Thomas	1.4	0.4	0.47	25	30	21
Stirling	1.7	0.4	0.4	28	26	18
Stratford	2.3	0.4	0.45	35	29	20
Strathroy	1.9	0.4	0.47	31	30	21
Sturge Falls	2.2	0.4	0.35	34	22	16
Sudbury	2.5	0.4	0.46	38	29	21
Sundridge	2.8	0.4	0.35	41	22	16
Tavistock	2.1	0.4	0.45	33	29	20
Temagami	2.6	0.4	0.37	39	24	17
Thamesford	1.9	0.4	0.48	31	31	22
Theford	2.1	0.4	0.5	33	32	22
Thunder Bay	2.9	0.4	0.39	42	25	18
Tillsburg	1.3	0.4	0.44	24	28	20
Timmins	3.1	0.3	0.35	42	22	16
Toronto	0.9	0.4	0.44	20	28	20
Trenton	1.6	0.4	0.47	27	30	21
Trout Creek	2.7	0.4	0.35	40	22	16
Uxbridge	2.4	0.4	0.42	36	27	19
Vaughan (Woodbridge)	1.1	0.4	0.44	21	28	20
Vittoria	1.3	0.4	0.47	24	30	21
Walkerton	2.7	0.4	0.5	40	32	22
Wallaceburg	0.9	0.4	0.45	20	29	20
Waterloo	2.0	0.4	0.37	32	24	17
Watford	1.9	0.4	0.47	31	30	21
Wawa	4.1	0.4	0.39	56	25	18
Welland	2.2	0.4	0.43	34	27	19
West Lorne	1.3	0.4	0.47	24	30	21
Whitby	1.2	0.4	0.48	23	31	22
Whitby (Brooklin)	1.9	0.4	0.45	31	29	20
White River	4.5	0.4	0.3	61	19	14
Warton	2.7	0.4	0.48	40	31	22
Windsor	0.8	0.4	0.47	20	30	21
Wingham	2.6	0.4	0.5	39	32	22
Woodstock	1.9	0.4	0.44	31	28	20
Wyoming	1.6	0.4	0.47	27	30	21

QUEBEC

City	Ss (kPa)	Sr (kPa)	Seismic Data	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
			S _s (0.2)		9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Acton-Vale	2.3	0.4		0.35	35	22	16
Alma	3.3	0.4		0.35	47	22	16
Amos	3.2	0.3		0.32	44	21	15
Aylmer,	2.5	0.4		0.41	38	26	18
Asbestos	2.8	0.6		0.35	45	22	16
Baie Comeau	4.3	0.4		0.50	58	32	22
Beauport	3.4	0.6		0.42	52	27	19
Bedford	2.1	0.4		0.41	33	26	18

City	S _s (kPa)	S _r (kPa)	Seismic Data	q _{1/50} (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
			S _a (0.2)		9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Beloeil	2.4	0.4		0.37	36	24	17
Brome	2.5	0.4		0.37	38	24	17
Brossard	2.4	0.4		0.42	36	27	19
Buckingham	2.6	0.4		0.40	39	26	18
Campbell's Bay	2.6	0.4		0.32	39	21	15
Chambly	2.3	0.4		0.40	35	26	18
Coaticook	2.3	0.6		0.35	39	22	16
Contrecoeur	2.8	0.4		0.43	41	27	19
Cowansville	2.3	0.4		0.41	35	26	18
Deux-Montagnes	2.4	0.4		0.37	36	24	17
Dolbeau	3.5	0.3		0.35	47	22	16
Drummondville	2.5	0.4		0.35	38	22	16
Farnham	2.2	0.4		0.37	34	24	17
Fort-Coulonge	2.5	0.4		0.32	38	21	15
Gagnon	4.6	0.4		0.39	62	25	18
Gaspé	4.3	0.6		0.48	62	31	22
Gatineau	2.5	0.4		0.41	38	26	18
Gracefield	2.6	0.4		0.32	39	21	15
Granby	2.3	0.4		0.35	35	22	16
Harrington-Harbour	4.9	0.6		0.72	69	46	32
Havre St-Pierre	4.1	0.6		0.63	60	40	28
Hemmingford	2.4	0.4		0.40	36	26	18
Iberville	2.2	0.4		0.41	34	26	18
Inukjuak	4.4	0.2		0.60	55	38	27
Joliette	3.1	0.4		0.36	44	23	16
Kuujuaq	4.8	0.2		0.60	60	38	27
Kuujuarapik	4.5	0.3		0.55	58	35	25
Lac Mégantic	3.2	0.6		0.35	50	22	16
Lachute	2.4	0.4		0.40	36	26	18
La-Tuque	3.4	0.4		0.35	48	22	16
Léry	2.3	0.4		0.42	35	27	19
Loretteville	3.7	0.6		0.41	56	26	18
Louiseville	2.9	0.4		0.43	42	27	19
Magog	2.3	0.4		0.35	35	22	16
Malartic	3.3	0.3		0.32	45	21	15
Maniwaki	2.4	0.4		0.31	36	20	14
Masson	2.4	0.4		0.40	36	26	18
Matane	3.7	0.4		0.60	51	38	27
Mont-Joli	4.0	0.4		0.52	55	33	23
Mont-Laurier	2.6	0.4		0.30	39	19	14
Montmagny *	2.9	0.6	0.73	0.47	46	30	21
Beaconsfield, Montréal	2.3	0.4		0.42	35	27	19
Dorval, Montréal	2.4	0.4		0.42	36	27	19
Laval, Montréal	2.6	0.4		0.42	39	27	19
Est, Montréal	2.7	0.4		0.42	40	27	19
Nitchequon	3.5	0.3		0.37	47	24	17
Noranda	3.2	0.3		0.35	44	22	16
Nord, Montréal	2.6	0.4		0.42	39	27	19
Outremont, Montréal	2.8	0.4		0.42	41	27	19
Percé	3.8	0.6		0.72	57	46	32

City	S _s (kPa)	S _r (kPa)	Seismic Data	q _{1/50} (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
			S _s (0.2)		9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Pierrefonds, Montréal	2.4	0.4		0.42	36	27	19
Pincourt, Montréal	2.3	0.4		0.42	35	27	19
Plessisville	2.8	0.6		0.35	45	22	16
Port-Cartier	4.1	0.4		0.54	56	34	24
Povirnitug	4.5	0.2		0.60	56	38	27
Richmond	2.2	0.6		0.35	38	22	16
Rimouski	3.8	0.4		0.52	53	33	23
Rivière-du-Loup *	3.3	0.6	1	0.50	51	32	22
Roberval	3.5	0.3		0.35	47	22	16
Rock-Island	2.0	0.4		0.35	32	22	16
Rosemère, Montréal	2.6	0.4		0.40	39	26	18
Rouyn	3.1	0.3		0.35	42	22	16
Saguenay	3.1	0.4		0.35	44	22	16
Salaberry-de-Valleyfield, Montréal	2.3	0.4		0.42	35	27	19
Schefferville	4.5	0.3		0.42	58	27	19
Senneterre	3.3	0.3		0.32	45	21	15
Sept-Îles	4.1	0.4		0.54	56	34	24
Shawinigan	3.1	0.4		0.35	44	22	16
Shawville	2.8	0.4		0.35	41	22	16
Sherbrooke	2.2	0.6		0.32	38	21	15
Sillery, Québec	3.1	0.6		0.41	49	26	18
Sorel	2.8	0.4		0.43	41	27	19
Ste-Agathe-des-Monts	3.4	0.4		0.35	48	22	16
Ste-Foy, Québec	3.7	0.6		0.41	56	26	18
St-Félicien	3.5	0.3		0.35	47	22	16
St-Georges-de-Cacouna *	3.2	0.6	0.8	0.80	50	51	36
St-Hubert, Montréal	2.5	0.4		0.42	38	27	19
St-Hubert-de-Riviere-du-Loup	4.4	0.6		0.40	64	26	18
St-Hyacinthe	2.3	0.4		0.35	35	22	16
St-Jérôme	2.7	0.4		0.37	40	24	17
St-Jovite	2.8	0.4		0.33	41	21	15
St-Nicolas	3.5	0.6		0.42	53	27	19
Sutton	2.4	0.4		0.41	36	26	18
Tadoussac	3.4	0.4		0.52	48	33	23
Témiscaming	2.5	0.4		0.32	38	21	15
Thetford Mines	3.3	0.6		0.35	51	22	16
Thurso	2.4	0.4		0.40	36	26	18
Trois-Rivières	2.8	0.4		0.43	41	27	19
Val-d'Or	3.4	0.3		0.32	46	21	15
Varennes	2.6	0.4		0.40	39	26	18
Verchères	2.7	0.4		0.43	40	27	19
Verdun, Montréal	2.5	0.4		0.42	38	27	19
Victoriaville	2.6	0.6		0.35	43	22	16
Ville-Centre, Montréal	2.6	0.4		0.42	39	27	19
Ville-Centre, Québec	3.6	0.6		0.41	54	26	18
Ville-Marie	2.3	0.4		0.40	35	26	18
Waterloo	2.5	0.4		0.35	38	22	16
Windsor	2.3	0.4		0.32	35	21	15

* Bracing to resist lateral loads due to earthquake should be provided (as per NBCC 2010 section 9.23.13)

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Alma	2.3	0.6	0.48	39	31	22
Bathurst	3.5	0.6	0.48	53	31	22
Campbellton	3.6	0.4	0.45	50	29	20
Edmundston	3.4	0.6	0.38	52	24	17
Fredericton	3.1	0.6	0.38	49	24	17
Gagetown	2.8	0.6	0.40	45	26	18
Grand Falls	3.6	0.6	0.38	54	24	17
Moncton	3.0	0.6	0.50	47	32	22
Oromocto	3.0	0.6	0.39	47	25	18
Sackville	2.5	0.6	0.49	42	31	22
Saint Andrews	2.3	0.6	0.45	39	29	20
Saint George	2.3	0.6	0.45	39	29	20
Saint John	2.3	0.6	0.53	39	34	24
Shippagan	3.4	0.6	0.63	52	40	28
St-Stephen	2.5	0.6	0.42	42	27	19
Woodstock	3.1	0.6	0.37	49	24	17

NOVA SCOTIA

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Amherst	2.4	0.6	0.48	41	31	22
Antigonish	2.1	0.6	0.54	37	34	24
Bridgewater	1.9	0.6	0.55	35	35	25
Canso	1.7	0.6	0.61	33	39	27
Debert	2.1	0.6	0.48	37	31	22
Digby	2.2	0.6	0.55	38	35	25
Greenwood(CFB)	2.7	0.6	0.54	44	34	24
Halifax (Dartmouth)	1.6	0.6	0.58	31	37	26
Halifax (City Centre)	1.9	0.6	0.58	35	37	26
Kentville	2.4	0.6	0.54	41	34	24
Liverpool	1.7	0.6	0.61	33	39	27
Lockeport	1.4	0.6	0.60	29	38	27
Louisburg	2.1	0.7	0.65	39	41	29
Lunenburg	1.9	0.6	0.61	35	39	27
New Glasgow	2.2	0.6	0.55	38	35	25
North Sydney	2.4	0.6	0.59	41	37	26
Pictou	2.2	0.6	0.55	38	35	25
Port Hawkesbury	2.1	0.6	0.74	37	47	33
Springhill	3.1	0.6	0.48	49	31	22
Stewiacke	1.8	0.6	0.50	34	32	22
Sydney	2.3	0.6	0.59	39	37	26
Tatamagouche	2.2	0.6	0.55	38	35	25
Truro	2.0	0.6	0.48	36	31	22
Wolfville	2.4	0.6	0.54	41	34	24
Yarmouth	1.8	0.6	0.56	34	36	25

PRINCE EDWARD ISLAND

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Charlottetown	2.7	0.6	0.56	44	36	25
Souris	2.7	0.6	0.58	44	37	26
Summerside	3.1	0.6	0.60	49	38	27
Tignish	3.2	0.6	0.66	50	42	29

NEWFOUNDLAND

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Argentia	2.4	0.7	0.75	43	47	33
Bonavista	2.8	0.6	0.84	45	53	37
Buchans	4.7	0.6	0.60	67	38	27
Cape Harrison	6.3	0.4	0.60	81	38	27
Cape Race *	2.3	0.7	1.05	42	66	47
Channel-Port aux Basques	3.0	0.7	0.78	50	49	35
Corner Brook	3.7	0.6	0.55	56	35	25
Gander	3.7	0.6	0.60	56	38	27
Grand Bank	2.4	0.7	0.74	43	47	33
Grand Falls	3.4	0.6	0.60	52	38	27
Happy Valley-Goose Bay	5.3	0.4	0.42	70	27	19
Labrador City	4.3	0.3	0.40	56	26	18
St-Anthony *	5.1	0.6	0.87	72	55	39
St-John's	2.9	0.7	0.78	48	49	35
Stephenville	3.5	0.6	0.58	53	37	26
Twin Falls	4.6	0.4	0.40	62	26	18
Wabana	3.0	0.7	0.75	50	47	33
Wabush	4.3	0.3	0.40	56	26	18

* Bracing to resist lateral loads due to wind should be provided (as per NBCC 2010 section 9.23.13)

YUKON

City	Ss (kPa)	Sr (kPa)	Seismic Data	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
			S _g (0.2)		9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Aishihik	1.9	0.1		0.38	24	24	17
Dawson	2.7	0.1		0.31	34	20	14
Destruction Bay *	1.6	0.1	0.73	0.60	21	38	27
Haines Junction *	2.2	0.1	0.72	0.34	28	22	15
Snag	2.2	0.1		0.31	28	20	14
Teslin	2.9	0.1		0.34	36	22	15
Watson Lake	3.1	0.1		0.35	38	22	16
Whitehorse	1.8	0.1		0.38	23	24	17

* Bracing to resist lateral loads due to earthquake should be provided (as per NBCC 2010 section 9.23.13)

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Aklavik	2.3	0.1	0.48	29	31	22
Echo Bay/Port Radium	3.0	0.1	0.53	37	34	24
Fort Good Hope	2.9	0.1	0.44	36	28	20
Fort Providence	2.4	0.1	0.35	30	22	16
Fort Resolution	2.3	0.1	0.39	29	25	18
Fort Simpson	2.3	0.1	0.39	29	25	18
Fort Smith	2.3	0.2	0.39	31	25	18
Hay River	2.4	0.1	0.35	30	22	16
Holman *	2.1	0.1	0.86	27	54	38
Inuvik	2.3	0.1	0.48	29	31	22
Mould Bay	1.5	0.1	0.58	20	37	26
Norman Wells	2.7	0.1	0.51	34	32	23
Rae-Edzo	2.3	0.1	0.47	29	30	21
Tungsten	4.3	0.1	0.44	52	28	20
Yellowknife	2.2	0.1	0.47	28	30	21

* Bracing to resist lateral loads due to wind should be provided (as per NBCC 2010 section 9.23.13)

NUNAVUT

City	Ss (kPa)	Sr (kPa)	q1/50 (kPa)	Snow Load (psf)	Wind Load (psf) - 4.1.7 NBCC 2010	
				9.4.2.2 NBCC 2010	Open terrain	Rough terrain
Alert	1.6	0.1	0.75	21	47	33
Arctic Bay	2.1	0.1	0.55	27	35	25
Arviat/Eskimo Point	2.9	0.2	0.58	38	37	26
Baker Lake	2.9	0.2	0.54	38	34	24
Cambridge Bay	1.6	0.1	0.54	21	34	24
Chesterfield Inlet	3.0	0.2	0.56	39	36	25
Clyde River	3.5	0.2	0.72	45	46	32
Coppermine	2.6	0.1	0.46	32	29	21
Coral Harbour	3.8	0.2	0.69	48	44	31
Eureka	1.6	0.1	0.55	21	35	25
Iqaluit	2.9	0.2	0.58	38	37	26
Isachsen	1.6	0.1	0.60	21	38	27
Nottingham Island	4.5	0.2	0.78	56	49	35
Rankin Inlet	3.0	0.2	0.60	39	38	27
Resolute	1.7	0.1	0.69	22	44	31
Resolution Island *	5.2	0.2	1.23	64	78	54

* Bracing to resist lateral loads due to wind should be provided (as per Part 4 of NBCC 2010 or accepted practices)

Great products are only the beginning.®



Boise Cascade Engineered Wood Products are manufactured by Boise Cascade
Distributed across Canada by CanWelBroadLeaf Building Materials Division
Sold by your better local building materials retailer


 www.canwelbroadleaf.com	Langley 5350 – 275th Street Langley, BC V4W 4A3 Phone: 604 607-6885 1 800 665-3448	Saskatoon 11 Capital Circle Corman Park, SK S7R 0H4 Phone: 306 933-2500 1 877 954-4448	Brampton 15 West Drive Brampton, ON L6T 3T5 Phone: 905 792-9903 1 800 792-9903	Dartmouth 70 Simmonds Drive Dartmouth, NS B3B 1P6 Phone: 902 468-9865 1 800 565-7913
	Kelowna 205 Campion Street Kelowna, BC V1X 7S9 Phone: 250 765-2036 1 877 488-8899	Regina 1055 Fleury Street Regina, SK S4N 4W9 Phone: 306 569-9071 1 800 567-6226	Ottawa 700 Industriel Avenue, Suite 401 Ottawa, ON K1G 0Y9 Phone: 613 247-8682 1 800 267-1305	Deer Lake 10 Spillway Road Dear lake, NL A8A 3E7 Phone: 709 635-4345 1 800 563-7517
	Calgary 4510 – 76th Ave S.E. Calgary, AB T2C 2V2 Phone: 403 279-7108 1 877 656-6166	Winnipeg 350 De Baets Street Winnipeg, MB R2J 0H4 Phone: 204 633-4890 1 800 665-1923	Blainville 651, boulevard Industriel Blainville, QC J7C 3V3 Phone: 450 435-6911 1 800 361-5345	St-John's 42 Sagona Avenue Donovans Industriel Park Mount-Pearl, NL A1N 4R3 Phone: 709 745-6760 1 888 745-6760
	Edmonton 11553 – 154th Street Edmonton, AB T5M 3N7 Phone: 780 451-3850 1 800 268-7569	Sudbury 725 Martindale Road Sudbury, ON P3E 4P8 Phone: 705 674-6469 1 800 461-1105	Québec 170, Liverpool St-Augustin-de-Desmaures, QC G3A 2M5 Phone: 418 878-6081 1 877 877-6081	

Your local retailer

The information provided herein was up-to-date at the time of printing. This document may be superseded by a updated version. Please confirm that this specifier guide is the most current version at www.bc.com/ewp.

The information in this document pertains to use in CANADA ONLY, Limit States Design. Refer to the US Tall Wall Specifier Guide for use in the United States.

455, boulevard Fénelon, suite 102
Dorval (Québec) H9S 5T8
ewp_canada@bc.com
www.BCewp.com



© 2011 Boise Cascade, L.L.C. BOISE, BOISE CASCADE, BCI, ALLJOIST, BC CALC, BC FRAMER, SawTek, SIMPLE FRAMING SYSTEM, VERSA-LAM, VERSA-STUD, and "Great products are only the beginning." are trademarks of Boise Cascade, L.L.C. or its affiliates.